

Installation and Operating Instructions for

ME807-16 Series TURBO-FLO LE Low Emission Shutoff Valve And ME135 Hose Discharge Coupling

!WARNING!

Failure to follow these instructions or to properly install and maintain this equipment could result in an explosion and/or fire causing property damage and personal injury or death.

MEC equipment must be installed, operated, and maintained in accordance with federal, state, and local codes and manufacturer's instructions. The installation in most states must also comply with NFPA No. 58, and ANSI Standard K61.1.


Only personnel trained in the proper procedures, codes, standards, and regulations of the LP-Gas industry should install and service this equipment.


Installation

!CAUTION!

Make sure all pressure is released from upstream piping before proceeding with installation.

- Apply Loctite #565 or suitable thread sealing compound to male NPT threads of mating pipe or fitting.
- Tighten connection by placing a suitable wrench on the wrench hex of the ME807 Turbo-Flo LE Shut-off Valve. Continue tightening the ME807 valve onto the pipe or fitting until the valve is upright (operating lever facing upward) when installed in final position.





 Connect a pressure source of a least 150 psi and check for leaks (as evidenced by bubbles) at all joints and sealing surfaces by applying a suitable leak detector solution to all joints. Ensure all connection joints are free of leaks before putting the ME807 LE valve into


Operation

!WARNING!

To avoid risk of serious injury or death, never attempt to open the ME807 Shut-off Valve when it is under pressure and not properly connected to transfer system. The ME807 Shut-off valve is equipped with a pilot equalization feature that will discharge a small amount of product if attempting to open when not properly connected to a transfer system.

 Connect Hose or Swivel Piping – With pump off, connect the ME806-16 TURBO-FLO LE Transfer Valve, or other transfer hose with standard 3 1/4" female acme connector, to the ME807 TURBO-FLO LE shut-off valve and tighten with appropriate wrench.

Note: When connecting a transfer hose equipped with an ME135 Hose Discharge Coupling, connect the discharge hose to the bleed-down line.





2. Open the Valve(s)

Warning:

When using a transfer hose, equipped with an ME135 or other discharge hose, the bleed-down line valve must be closed prior to opening the transfer valve.

- Open the ME807-16 TURBO-FLO LE shut-off valve by releasing the locking latch and moving the handle toward the acme connection.
 - Note: A slight motion of the handle opens a pilot orifice that equalizes the pressure on both sides of the valve. Once equalized, the valve will open fully with continued pressure on the handle. Once opened, the valve will remain open until the handle is moved to the closed position (away from the acme connection). If the valve does not open fully with reasonable pressure on the handle, check to make sure the latch is pulled all the way out of the locking notches in the valve casting and the hose-end valve is fully closed.
- b. Open the connected ME806-16 TURBO-FLO LE Transfer valve, other hose end valve, or system shut-off valve.

Marshall Excelsior Company, 1506 George Brown Drive Marshall, MI 49068 Phone (269) 789-6700 Fax (269) 781-8340, www.marshallexcelsior.com

The contents of this publication are for informational purposes only. While every effort has been made to ensure accuracy, these contents are not to be construed as warranties or guarantees, expressed or implied, regarding the products or services described herein or for their use or applicability. Marshall Excelsior Co. reserves the right to modify or improve the designs or specifications of such products at any time without notice. The MECTM logo in the trademark of Marshall Excelsior Co.

Form #970 Rev A

- Transfer Product Turn pump on and follow safe filling / transfer practices as outlined in the NFPA 58, national fuel gas code. Note: In case of emergency, the ME807 Shut-off Valve can be closed instantly by snapping the spring loaded handle to the closed position (away from the acme connection).
- 4. End Transfer Turn off pump, close the ME806-16 TURBO-FLO LE Transfer Valve or other hose end valve. Close ME807 TURBO-FLO LE Shut-off Valve by pushing the handle away from the acme adapter until the handle safety latch locks in the closed position. When using a bleed-down discharge hose (such as ME135 hose discharge coupling), completely bleed all line pressure before disconnecting acme connection. Disconnect transfer valve.

!WARNING!

NEVER disconnect the ME807 Shut-off Valve with the valve open. Make sure the safety latch is in the locked position (both sides of the latch engaged in notches on body) before disconnecting valve. Note: this valve system is designed for minimum product loss at disconnect. To achieve the intended low emission feature of this transfer system, you may need to adjust your standard operating procedure for the filling process.

!WARNING!

- To avoid risk of serious injury or death, never attempt to open the ME807 Shut-off Valve when it is under pressure and not properly connected to the system with an appropriate transfer hose.
- Remove valve from service immediately if the safety latch does not function properly
- Remove valve from service immediately if valve seals or joints leak

Acme Adapter Service and Replacement Instructions

!WARNING!

Failure to follow the adapter service and replacement instructions could cause risk of serious injury or death.

- Release all system pressure before attempting to service the adapter.
- 2. Remove the (2) Set Screws [2] from Body [1] that retain the Adapter [3] and discard.
- 3. Remove the Adapter [3] from the Body [1] casting using the appropriate wrench on the wrench flats provided.
- 4. Remove Seal [4] from the Body [1] and discard.
- Clean all threads and sealing surfaces and install new Seal [4] into Body [1] casting.
- 6. Apply Loctite #242 (blue) or equivalent thread locker to Adapter [3] and torque to 160 to 180 Ft-lbs.
 - **Note:** If using an Acme Cap to install, leave Cap in place until after set screws are installed in step 7.
- 7. Install new Set Screws [2] and torque as follows:

Brass Adapter: 50 In-lbs Steel Adapter: 80 In-lbs

Warning: Use only the (2) Set Screws [2] provided with service kit.

 Connect a pressure source of a least 150 psi and check for leaks (as evidenced by bubbles) at all joints and sealing surfaces by applying a suitable leak detector solution to all joints

Component List

ME807-16-01 Valve Body
ME807-16-07 Set Screw, Qty: 2

3. Adapter

ME807-16-02 BrassME807S-16-02 Steel

ME806HN-16-07 Adapter O-Ring



Preventative Maintenance and Safety Checks

The ME807 Shut-off Valve is designed to provide a long and trouble free service life when properly installed and maintained. Like all mechanical devices, however, it is subject to wear and requires preventative maintenance to maintain safe and efficient operation. Perform the inspections and service as follows:

Before each use:

- Inspect the safety latch to ensure that it is in the locked position (both sides of the latch engaged in notches on body) prior to and after each use. If it is not fully latched, move the handle grip away from the acme adapter until latch is fully engaged.
- Inspect acme adapter for worn threads. Replace adapter if required. See "Periodic Checks" for important safety instructions regarding the acme adapter.

Periodic Checks

The following checks should be performed weekly on valves exposed to severe service conditions such as frequent use (over 100 connections per week) or when exposed to contaminants, corrosive agents or extreme weather conditions. The checks should be performed at least monthly on all other valves.

- Handle assembly Inspect the valve handle, latch and springs for proper operation. If service is required. Have handle assembly replaced by qualified service personnel using the service instructions provided with the replacement parts. WARNING: Remove valve from service immediately if the safety latch does not function properly.
- 2. Seals Inspect the valve seals for leaks (as evidenced by bubbles) at all joints and sealing surfaces by apply Marshall Excelsior "Leak Detector" solution to all joints. If service is required, have leak repaired by qualified service personnel using the service instructions provided with the replacement parts. WARNING: Remove valve from service immediately if valve seals or joints leak.

Form #970 Rev A